



NOTES:

1. APPROVED LEAD FREE DOUBLE CHECK VALVE DEVICES ARE LISTED IN THE USC LIST OF APPROVED DOUBLE CHECK VALVE ASSEMBLIES. INSTALLATION OF THE DEVICE SHALL BE IN A LOCATION ACCESSIBLE BY THE CITY.
2. ALL FITTINGS, PIPE, VALVES, AND FIXTURES SHALL BE LEAD FREE IN COMPLIANCE WITH FEDERAL AND STATE LAWS.

ITEM MATERIALS

- | | |
|---|-------------------------------------------------------------------------------------------------------------------------|
| ① | WATER METER. SEE STD 408 FOR A 1-INCH WATER CONNECTION DETAIL, STD 409 FOR A 1½-INCH OR 2-INCH WATER CONNECTION DETAIL. |
| ② | DOMESTIC WATER SERVICE TO INDIVIDUAL UNITS PER SEPARATE BUILDING PLAN SUBMITTAL. |
| ③ | FIRE SERVICE TO INDIVIDUAL UNITS PER SEPARATE UNDERGROUND FIRE PLAN. |
| ④ | APPROVED DOUBLE CHECK VALVE PER NOTE 1. |

NOT TO SCALE

COURTYARD POTABLE WATER SERVICE CONNECTION DETAIL

REVISION			APPROVED:		DATE	
NO.	APPROVED	DATE				
			 TOM G. KOPER, PE, CITY ENGINEER		1/7/2019	
			 VERNON R. WEISMAN, PE, DISTRICT ENGINEER		1/7/2019	

CITY OF CORONA
THE CORONA CITY

CITY OF CORONA

STD 425

SHEET 1 OF 1