


* DIMENSION MAY VARY FOR SPECIAL CIRCUMSTANCES.


- | ITEM | MATERIALS |
|------|--|
| 1 | DOUBLE STRAP LEAD-FREE SADDLE FOR AC, CIP, DIP AND PVC PIPES: JONES J-969 OR J-969W SERIES, FORD STYLE 202BSD OR STYLE 202BS, MUELLER BR2S OR BR2W SERIES, OR A.Y.MCDONALD 3825 OR 3826. |
| 2 | CORPORATION STOP (BALL VALVE) (MIP x CTS COMPRESSION): JONES E1935SG, FORD FB1000-3-Q-NL OR FB1000-4-Q-NL, MUELLER B-25028N OR A.Y.MCDONALD 74704BQ. |
| 3 | 1-INCH COPPER TUBING TYPE "K". |
| 4 | ANGLE METER STOP (BALL VALVE) (CTS COMPRESSION x MSN): JONES E-1963WSG, FORD BA43-444W-NL, MUELLER B-24258N OR A.Y.MCDONALD 74602BQ. |
| 5 | DFW DFWPW6C4-12-4F LLDPE METER BOX AND HDPE COVER WITH READING LID H-20 RATING LABELED "WATER" 16 ⁵ / ₁₆ " x 31 ³ / ₄ " x 12" INSIDE DIMENSIONS. |
| 9 | 1/2" THICK FLEXIBLE VINYL (PVC) EXPANSION JOINT WITH A MINIMUM 2" DEPTH. INSTALL EXPANSION JOINT WHEN METER BOX IS CAST IN CONCRETE. DO NOT USE FABRIC OR FELT. |

CONSTRUCTION NOTES:

- SERVICE SADDLE SHALL NOT BE INSTALLED WITHIN 12 INCHES OF VALVE, COUPLING, JOINT, OR FITTING.
- DOUBLE-WRAP ALL PIPING BELOW GRADE IN PURPLE COLORED 8-MIL POLYETHYLENE SLEEVES LABELED RECLAIMED WATER. EXTEND POLYETHYLENE SLEEVES 2 INCHES MINIMUM ABOVE FINISH GRADE. SECURE WITH 10-MIL TAPE.
- CONSTRUCT WATER SERVICE PIPE IN SAND BEDDING (SE 30 MINIMUM) FROM CORP STOP TO METER BOX.
- ALL CONNECTIONS TO COPPER TUBING SHALL BE COMPRESSION TYPE AND SERVICE MUST BE CONTINUOUS AND UNCUT. NO SWEAT TYPE FITTINGS ALLOWED.
- CONNECTIONS TO STEEL WATER MAINS SHALL BE WITH A WELDED 3000 POUND HALF COUPLING AND DIELECTRIC INSULATING BUSHING. ALL STEEL SURFACES SHALL BE COVERED WITH CEMENT MORTAR.
- ROUND AND DE-BURR ALL COPPER PIPE PRIOR TO INSTALLATION.
- WRAP SERVICE SADDLE WITH TWO LAYERS OF 8-MIL PURPLE POLYETHYLENE.
- INSTALL BRASS PIPING AND FITTINGS INSIDE METER BOX BETWEEN ANGLE METER STOP AND BRASS UNIONS.
- PROVIDE METER BOXES IN UNIMPROVED STREETS AND BEHIND ROLLED CURBS WITH COVERS AND BOXES RATED FOR H-20 TRAFFIC LOADS.
- AMI (ADVANCE METERING INFRASTRUCTURE) METERS ARE REQUIRED WHEN THE METER WILL BE READ VIA RADIO SIGNAL. CONTACT A PUBLIC WORKS ENGINEER TO DETERMINE IF THE METER(S) FOR THE PROJECT ARE REQUIRED TO BE AMI. **NOT TO SCALE**

1" RECLAIMED WATER SERVICE CONNECTION DETAIL

REVISION			APPROVED:			CITY OF CORONA
NO.	APPROVED	DATE		10/01/20		STD 414R
3		05/04/18	<i>Tom Koper</i>	DATE		
4		12/28/18	TOM G. KOPER, PE, CITY ENGINEER			
5	VRW	10/01/20	<i>Vernon R. Weisman</i>	10/01/20		
			VERNON R. WEISMAN, PE, DISTRICT ENGINEER	DATE		



CONSTRUCTION NOTES:




1. SEE CONSTRUCTION NOTES ON SHEET 1.
2. INSTALL A "LOCK OFF" STYLE BALL VALVE FOR THE RECLAIMED WATER SERVICE.
3. THE WATER SERVICE SHALL EXTEND PERPENDICULAR TO THE CENTERLINE OF THE STREET FROM THE WATER MAIN TO THE METER STOP.
4. THE CONTRACTOR IS RESPONSIBLE FOR THE COMPLETE SERVICE CONNECTION AS SHOWN ON THIS STANDARD PLAN EXCEPT FOR THE WATER METER. CITY WILL PROVIDE AND INSTALL A NEPTUNE T-10 METER. REQUEST THE METER INSTALLATION FROM THE PUBLIC WORKS INSPECTOR OR THE BUILDING INSPECTOR WHEN THERE IS NO PUBLIC IMPROVEMENT PLAN.
5. A REDUCER FITTING CAN BE INSTALLED BETWEEN THE ANGLE METER STOP VALVE AND THE METER, AND PAST THE BRASS UNION WITHIN THE PRIVATE OWNER MAINTAINED AREA.
6. ALL FITTINGS, PIPE, VALVES, AND FIXTURES SHALL BE LEAD FREE IN COMPLIANCE WITH FEDERAL AND STATE LAWS.

ITEM MATERIALS

- 4 — ANGLE METER STOP (BALL VALVE) (CTS COMPRESSION x MSN): JONES E-1963WSG, FORD BA43-444W-NL, MUELLER B-24258N OR A.Y.MCDONALD 74602BQ.
- 6 — METER VALVE (FIP x MSN): JONES STYLE E-1903W, FORD STYLE B13-344W-NL OR STYLE B13-444W-NL, MUELLER B24351N OR A.Y.MCDONALD 76101MW WITH "LOCK OFF" HANDLE.
- 7 — RED BRASS NIPPLE (MIP x MIP), THREADED BOTH ENDS, 1-1/2-INCH LENGTH.
- 8 — BRASS UNION (FIP x FIP).
- 9 — 1/2" THICK FLEXIBLE VINYL (PVC) EXPANSION JOINT WITH A MINIMUM 2" DEPTH. INSTALL EXPANSION JOINT WHEN METER BOX IS CAST IN CONCRETE. DO NOT USE FABRIC OR FELT.

NOT TO SCALE

1" RECLAIMED WATER SERVICE CONNECTION DETAIL

REVISION			APPROVED:			CITY OF CORONA	
NO.	APPROVED	DATE				STD 414R	
3		05/04/18	 TOM G. KOPER, PE, CITY ENGINEER			10/01/20	
4		12/28/18	 VERNON R. WEISMAN, PE, DISTRICT ENGINEER			10/01/20	
5	VRW	10/01/20				SHEET 2 OF 2	