



# Corona Fire Department

## Industrial Oven Guideline per 2022 California Fire Code

### PURPOSE

The intent of this guideline is to provide the minimum standards necessary for the installation and operation of industrial ovens and furnaces. Industrial ovens and furnaces shall comply with the applicable provisions of the International Fuel Gas Code, the California Mechanical Code, NFPA 86 and this chapter.

### SCOPE

This guideline applies to industrial ovens and furnaces installed and operated in the City of Corona. The terms “ovens” and “furnaces” are used interchangeably in this chapter.

### DEFINITIONS

#### **Furnace – Class A**

An oven or furnace that has a heat utilization equipment operating at approximately atmospheric pressure wherein there is a potential explosion or fire hazard that could be occasioned by the presence of flammable volatiles or combustible materials processed or heated in the furnace.

Note: Such materials may result from the following:

1. Paints, powders, inks, and adhesives from finishing processes, such as dipped, coated, sprayed and impregnated materials.
2. The substrate material.
3. Wood, paper and plastic pallets, spacers, or packaging materials.
4. Polymerization or other molecular rearrangements.

Potentially flammable materials, such as quench oil, water-borne finishes, cooling oil or cooking oils that present a hazard are ventilated according to Class A standards.

#### **Furnace – Class B**

An oven or furnace that has heat utilization equipment operating at approximately atmospheric pressure wherein there are no flammable volatiles or combustible materials being heated.

#### **Furnace – Class C**

An oven or furnace that has a potential hazard due to a flammable or other special atmosphere being used for treatment of materials in process. This type of furnace can use any type of heating system and includes a special atmosphere supply system. Also included in the Class C classification are integral quench furnaces and molten salt bath furnaces.

#### **Furnace – Class D**

An oven or furnace that operates at temperatures from above ambient to over 5000°F and at pressures normally below atmospheric using any type of heating system. These furnaces can include the use of special processing atmospheres.



# Corona Fire Department

## Industrial Oven Guideline per 2022 California Fire Code

### REQUIREMENTS

1. Location of furnaces or ovens shall be in accordance with CFC 3003.
  - a. Ventilation: Enclosed rooms containing ovens or furnaces shall be provided with combustion air and ventilation air in accordance with the *International Fuel Gas Code* and the *California Mechanical Code*, and with ventilation air in accordance with the *California Mechanical Code*.
  - b. Exposure: When locating ovens, oven heaters and related equipment, the possibility of fire resulting from overheating or from the escape of fuel gas or fuel oil and the possibility of damage to the building and injury to persons resulting from explosion shall be considered. CFC 3003.2.
  - c. Ignition Source: Industrial ovens and furnaces shall be located so as to not pose an ignition hazard to flammable vapors, mists or combustible dusts, per CFC 3003.3.
  - d. Temperatures: Roofs and floors of ovens shall be insulated and ventilated to prevent temperatures at combustible ceilings and floors from exceeding 160°F, (71°C) per CFC 3003.4.
2. Fuel-gas piping serving industrial ovens shall comply with the *International Fuel Gas Code*. Piping for other fuel sources shall comply with this section.
  - a. Each industrial oven or furnace shall be provided with an approved manual fuel shutoff valve in accordance with the *International Fuel Gas Code* or the *California Mechanical Code*. per CFC 3004.2.
  - b. Valves for fuel supply lines shall be located within 6'(1829 mm) of the appliance served.  
Exception: When approved and the valve is located within the same general area as the appliance it serves.
  - c. The manual fuel shut-off valve shall provide permanent visual indication of the valve being open or closed. Manual fuel shut off valves shall not be provided with removable handles or wrenches unless approved and can only be installed parallel with the fuel line when the valve is in the open position.
3. Interlocks shall be provided for Class A ovens so that conveyors or sources of flammable or combustible materials shall shut down if either the exhaust or the recirculation air supply fails, per CFC 3005.1.
4. Fire protection shall be provided in accordance with CFC 3006.
  - a. Class A and B ovens which contain or are used for the processing of combustible materials shall be protected by an approved automatic fire extinguishing system complying with CFC Chapter 9.
  - b. Fixed-fire extinguishing systems shall be provided for Class C or D ovens to protect against such hazards as overheating, spillage of molten salts or metals, quench tanks, ignition of hydraulic oil and escape of fuel. It shall be the responsibility of the owner to consult with the fire code official regarding the necessary requirements.
  - c. Portable fire extinguishers complying with CFC 906 shall be provided no closer than 15' or a maximum of 50'in accordance with NFPA 10. This shall apply to the oven and related equipment.
5. Furnace system information shall be posted on an approved, clearly worded, and prominently displayed safety design data form or manufacturer's nameplate. Such information shall include the safe operating condition for which the system was designed, built, altered or extended, per CFC 3007.1.



# Corona Fire Department

## Industrial Oven Guideline per 2022 California Fire Code

6. Safety data for Class A solvent atmosphere ovens shall be provided on the manufacturer's nameplate. In accordance with CFC 3007.2, the nameplate shall also provide the following:
  - a. The solvent used.
  - b. The number of gallons used per batch or per hour of solvent entering the oven.
  - c. The required purge time.
  - d. The oven operating temperature.
  - e. The exhaust blower rating for the number of gallons of solvent per hour or batch at the maximum operating temperature.

Exception: For low-oxygen ovens, the maximum allowable oxygen concentration shall be included in the place of the exhaust blower ratings.
7. Operating, maintenance and supervisory personnel shall be trained in the operation of the equipment, per CFC 3007.3. Training documentation shall be available to the authority having jurisdiction upon request.
8. Equipment shall be maintained in accordance with the manufacturer's instructions per CFC 3007.4. Maintenance documentation shall be available to the authority having jurisdiction upon request.