



Corona Fire Department

Tents and Membrane Structures Guidelines per 2022 California Fire Code

PURPOSE

The intent of this guideline is to provide the minimum standards needed to obtain a permit to erect tents, temporary special event structures and other membrane structures.

SCOPE

This guideline shall apply to tents and other membrane structures having an area in excess 400 square feet. The requirements are from 2022 California Fire Code (CFC) Chapter 31 and California Code of Regulations (CCR) Title 19. Please refer to the Special Events Fire Code Permit Application for application details.

GUIDELINES

- A. A California Fire Code permit is required to erect a tent or membrane structure in excess of 400 sf.
- Exception: Tents open on all sides, complying with the following:
- Individual Tents not exceeding 700 sf, open on all sides,
 - The aggregate area of multiple tents placed side by side without a fire break clearance of not less than 12' shall not exceed 700 sf total.
 - A minimum clearance of 12' to structures and other tents shall be provided.
- B. The following information is required to obtain a permit for a temporary tent or membrane structure:
1. Temporary tents and membrane structures shall not be located within 20 feet of lot lines, buildings, other tents or membrane structures, parked vehicles, or internal combustion engines. For the purpose of determining required distances, support ropes and guy wires shall be considered as part of the temporary tent or membrane structure.
 2. Vehicles necessary to the operation of the establishment shall be parked at least 20' from any tent. All other vehicles shall be parked at least 100' from any tent except vehicles parked on a public street, which shall park at least 20' from any tent, per the regulation of the State Fire Marshal (CFC 3103.8.2).
 3. Tents or membrane structures, temporary special event structures and their appurtenances shall be designed and installed to withstand the elements of weather and prevent collapsing. Documentation of structural stability shall be furnished to the fire code official for review by the Building Department. CFC 3103.9
 4. Dimensions and specifications for all temporary tents and membrane structures shall be provided.
 - a. An unobstructed fire break passageway or fire road not less than 12' wide and free from guy ropes or other obstructions shall be maintained on all sides of all tents and membrane structures unless otherwise approved by the fire code official, per CFC 3103.8.6.
 5. Proposed seating and exiting arrangements (CFC 3103.11 and Chapter 10)
 - a. The occupant load shall be provided in accordance with CFC 3107.11 and Chapter 10.
 - Maximum occupant load shall be posted when greater than 50 persons.
 - A place of assembly permit is required when greater than 50 persons.
 - b. Flame retardant certificate(s) for tent material per CFC 3104.2.
 - Certification executed by an approved testing laboratory certifying that all tents and membrane structures, their appurtenances; sidewalls, drops and tarpaulins; floor coverings, bunting and combustible decorative materials and effects, including sawdust when used on floors or passageways.



Corona Fire Department

Tents and Membrane Structures Guidelines per 2022 California Fire Code

CODE REQUIREMENTS

A. EXITS

1. Exits shall be spaced at approximately equal intervals around the perimeter of the tent, or membrane structure and shall be located such that all points are 100' or less from an exit, per CFC 3103.12.1 through 3103.12.8.
2. Tents, membrane structures or temporary special event structures or a usable portion thereof shall have at least one exit and not less than the number of exits required by Table 3103.12.2. The total width of means of egress in inches shall not be less than the total occupant load served by a means of egress multiplied by 0.2 inches per person.
3. Exit openings from tents shall remain open unless covered by a flame-resistant curtain, as required by CFC 3103.12.3, provided that:
 - a. Curtains shall be free sliding on a metal support. The support shall be a minimum of 80" above the floor level at the exit. The curtain shall be so arranged such that, when open, no part of the curtain obstructs the exit.
 - b. Curtains shall be of a color, or colors, that contrast with the color of the tent.
4. Exit doors shall swing in the direction of exit travel. To avoid hazardous air and pressure loss in air supported membrane structures, such doors shall be automatic closing against operating pressures. Opening force at the door edge shall not exceed 15 pounds.

Table 3103.12.2 EXITS FROM TEMPORARY MEMBRANE STRUCTURES AND TENTS¹

Occupant Load	Minimum number of means of egress	Minimum width of each means of egress (inches)	
		Tent	Membrane Structure
10 to 199	2	72	36
200 to 499	3	72	72
500 to 999	4	96	72
1000 to 1999	5	120	96
2000 to 2999	6	120	96
Over 3000	7	120	96

5. The width of aisles without fixed seating shall be as follows, per CFC 3103.12.5:
 - a. In areas serving employees only, the minimum aisle width shall be 24 inches but not less than the width required by the number of employees served
 - b. In public areas, smooth-surfaced, unobstructed aisles having a minimum width of not less than 44 inches shall be provided from seating areas, and aisles shall be progressively increased in width to provide, at all points, not less than 1 foot of aisle width for each 50 persons served by such aisle at that point.
 - c. The arrangement of aisles shall be subject to approval by the fire code official and shall be maintained clear at all times during occupancy.
6. Means of egress shall be illuminated with light having an intensity of not less than 1 foot candle at floor level while the structure is occupied per CFC 3103.12.7. Fixtures required for means of egress illumination shall be supplied from a separate circuit or source of power.
7. Exit signage shall be clearly marked per CFC 3103.12.6. Exit signs shall be installed where necessary to clearly identify the direction of travel when the exit serves an occupant load of 50 or more.

¹ When the occupant load exceeds 3000, the total width of means of egress (in inches) shall not be less than the total occupant load multiplied by 0.2 inches per person.



Corona Fire Department

Tents and Membrane Structures Guidelines per 2022 California Fire Code

EXIT signs shall be either listed or labeled in accordance with UL 924 as the internally illuminated type and used in accordance with the listing, or shall be externally illuminated by luminaires supplied in the following manner:

- a. Two separate circuits, one of which shall be separate from all other circuits, for occupant loads of 300 or less; or
 - b. Two separate sources of power, one of which shall be an approved emergency system, shall be provided when the occupant load exceeds 300. Emergency systems shall be supplied from storage batteries from the on-site generator set, and the system shall be installed in accordance with the California Electrical Code and CFC 3103.10.4. The emergency system provided shall have a minimum duration of 90 minutes when operated at full design demand.
8. The required width of exits, aisles and passageways shall be maintained at all times to a public way. Guy wires, guy ropes and other support members shall not cross a means of egress at a height of less than 8'. The surface of means of egress shall be maintained in an approved manner per CFC 3103.12.8.

B. SEATING

1. Assembly occupancies which contain seats, tables, displays, equipment or other material shall meet the requirements of CFC 1029.
2. Places of assembly without ramped or tiered floors for seating and with greater than 200 seats, shall have the seats fastened together in groups of not less than three, or the seats shall be securely fastened to the floor per CFC 1029.14.

C. FIRE EXTINGUISHERS

1. Portable fire extinguishers shall be provided. Travel distance to the nearest 2A:10BC extinguisher shall not exceed 75', per CFC 906 and 3106.4.4. At least one Class 10BC extinguisher shall be provided at generators or transformers.
2. Portable fire extinguishers shall be located in conspicuous locations where they will be readily accessible and immediately available for use. These locations shall be along normal paths of travel, unless the fire code official determines that the hazard posed indicates the need for placement away from normal paths of travel, per CFC 906.5
3. Fire extinguishers provided for the protection of cooking grease fires shall be Class K, per CFC 906.4.

D. HEATING AND COOKING EQUIPMENT

1. Heating or cooking equipment, tanks, piping, hoses, fittings, valves, tubing, and other related components shall be installed as specified in the CA Mechanical Code and shall be approved by the fire code official.
2. Electrical heating and cooking equipment shall comply with the California Electrical Code per CFC 3107.12.7.
3. Cooking and heating equipment shall not be located within 10 feet of exits or combustible materials per CFC 3107.12.3.
4. Tents with sidewalls or drops where cooking is performed shall be separated from other tents or membrane structures by a minimum of 20' per CFC 3107.12.5.
5. Outdoor cooking that produces sparks or grease-laden vapors shall not be performed within 20' of a tent, or membrane structure per CFC 3107.12.6.
6. Operations such as warming of foods, cooking demonstrations and similar operations that use solid flammables, butane or other similar devices which do not pose an ignition hazard, shall be approved per CFC 3107.12.4.



Corona Fire Department

Tents and Membrane Structures Guidelines per 2022 California Fire Code

E. FLAMMABLE AND COMBUSTIBLE LIQUIDS/GASES

1. Flammable-liquid-fueled equipment shall not be used in tents or membrane structures per CFC 3107.14.
2. Flammable or combustible liquids shall be stored outside in an approved manner not less than 50' from tents, or membrane structures, per CFC 3107.14.2.
3. Refueling shall be performed in an approved location not less than 20 feet from tents, or membrane structures per CFC 3107.14.3.

F. LP-GAS

1. LP-gas containers shall be located outside. Safety release valves shall be pointed away from the tent or membrane structure per CFC 3107.13.2.
2. Portable LP-gas containers with a capacity of 500 gallons or less shall have a minimum separation between the container and the structure not less than 10', per CFC 6104. Table 6104.3
3. Portable LP-gas containers with a capacity of more than 500 gallons shall have a minimum separation between the container and structures not less than 25', per CFC 6104. Table 6104.3.
4. Portable LP-gas containers, piping, valves and fittings which are located outside and are being used to fuel equipment inside a tent or membrane structure shall be adequately protected to prevent tampering, damage by vehicles or other hazards and shall be located in an approved location. Portable LP-gas containers shall be securely fastened in place to prevent unauthorized movement, per CFC 3107.13.3.

G. HOUSEKEEPING

1. Combustible vegetation shall be removed from the area occupied by a tent or membrane structure, and from areas within 30' of such structures per CFC 3107.18.
2. The floor surface inside tents or membrane structures and the grounds outside and within a 30' perimeter shall be kept clear of combustible waste. Such waste shall be stored in approved containers until removed from the premises, per CFC 3107.19.

H. STANDBY PERSONNEL

1. When, in the opinion of the fire code official, it is essential for public safety in a tent or membrane structure used as a place of assembly or any other use where people congregate, because of the number of persons, or the nature of the performance, exhibition, display, contest or activity, the owner, agent or lessee shall employ one or more qualified persons, as required and approved, to remain on duty during such times such places are open to the public, or when such activity is being conducted, per CFC 3107.17.
2. There shall be trained crowd managers or crowd manager supervisors at a ratio of one crowd manager/supervisor for every 250 occupants, as approved. At least one qualified fire safety person shall be present in every tent having a capacity of 500 or more and one additional qualified person for each 1000 additional persons or fraction thereof shall be present, per CCR T-19, Chapter 2, §320.

I. USE PERIOD

1. Temporary tents, air-supported, air inflated or tensioned membrane structures shall not be erected for a period of more than 180 days within a 12-month period on a single premises.