



Received

MAY - 4 2009

1995 MARKET STREET
RIVERSIDE, CA 92501
951.955.1200
FAX 951.788.9965
http://www.floodcontrol.co.riverside.ca.us
51190_7

Community Development Dept

RIVERSIDE COUNTY FLOOD CONTROL
AND WATER CONSERVATION DISTRICT

City of Corona
Post Office Box 940
400 South Vicentia Avenue
Corona, CA 92882

Attention: Jason Moquin

Re: NOTICE OF Preparation
DRAFT ENVIRONMENTAL IMPACT REPORT

Ladies and Gentlemen:

The District does not normally recommend conditions for land divisions or other land use cases in incorporated cities. The District also does not plan check city land use cases, or provide State Division of Real Estate letters or other flood hazard reports for such cases. District comments/recommendations for such cases are normally limited to items of specific interest to the District including District Master Drainage Plan facilities, other regional flood control and drainage facilities which could be considered a logical component or extension of a master plan system, and District Area Drainage Plan fees (development mitigation fees). In addition, information of a general nature is provided.

The District has not reviewed the proposed project in detail and the following checked comments do not in any way constitute or imply District approval or endorsement of the proposed project with respect to flood hazard, public health and safety or any other such issue:

- No comment.
- This project would not be impacted by District Master Drainage Plan facilities nor are other facilities of regional interest proposed.
- This project involves District Master Plan facilities. The District will accept ownership of such facilities on written request of the City. Facilities must be constructed to District standards, and District plan check and inspection will be required for District acceptance. Plan check, inspection and administrative fees will be required.
- This project proposes channels, storm drains 36 inches or larger in diameter or other facilities that could be considered regional in nature and/or a logical extension of the adopted Master Drainage Plan. The District would consider accepting ownership of such facilities on written request of the City. Facilities must be constructed to District standards, and District plan check and inspection will be required for District acceptance. Plan check, inspection and administrative fees will be required.
- This project is located within the limits of the District's Area Drainage Plan for which drainage fees have been adopted; applicable fees should be paid by cashier's check or money order only to the Flood Control District or City prior to issuance of grading permits. Fees to be paid should be at the rate in effect at the time of issuance of the actual permit.
- An encroachment permit shall be obtained for any construction related activities occurring within District right of way or facilities. For further information, contact the District's encroachment permit section at 951.955.1266.

GENERAL INFORMATION

This project may require a National Pollutant Discharge Elimination System (NPDES) permit from the State Water Resources Control Board. Clearance for grading, recordation or other final approval should not be given until the City has determined that the project has been granted a permit or is shown to be exempt.

If this project involves a Federal Emergency Management Agency (FEMA) mapped flood plain, then the City should require the applicant to provide all studies, calculations, plans and other information required to meet FEMA requirements, and should further require that the applicant obtain a Conditional Letter of Map Revision (CLOMR) prior to grading, recordation or other final approval of the project, and a Letter of Map Revision (LOMR) prior to occupancy.

If a natural watercourse or mapped flood plain is impacted by this project, the City should require the applicant to obtain a Section 1602 Agreement from the California Department of Fish and Game and a Clean Water Act Section 404 Permit from the U.S. Army Corps of Engineers, or written correspondence from these agencies indicating the project is exempt from these requirements. A Clean Water Act Section 401 Water Quality Certification may be required from the local California Regional Water Quality Control Board prior to issuance of the Corps 404 permit.

Very truly yours,

DALE V. ANDERSON
Engineering Project Manager

Date: April 28, 2009

c: Riverside County Planning Department
Attn: Kathleen Browne

J.G.