

- 1. ALL CONCRETE SHALL BE CLASS 560-C-3250, CURED WITH CURING COMPOUND.
- 2. ALL EXISTING PCC TO BE REMOVED SHALL BE SAWCUT AT THE JOINTS.
- 3. DRIVEWAYS WITH 14'≤"W"≤20' SHALL HAVE 1 WEAKENED PLANE JOINT AT 1/2W. DRIVEWAYS WITH W>20' SHALL HAVE WEAKENED PLANE JOINTS AT NOT TO EXCEED 7' ON CENTER.
- FOR NEW DRIVEWAY APPROACHES ON EXISTING STREETS, A 12" WIDTH OF ASPHALT CONCRETE SHALL BE REMOVED AND REPLACED.
- 5. DRIVEWAYS FOR CORNER LOTS SHALL BE LOCATED ADJACENT TO THE PROPERTY LINE AWAY FROM THE INTERSECTION.
- W DIMENSION SHALL MATCH WIDTH OF GARAGE(S) UNLESS OTHERWISE APPROVED BY THE PUBLIC WORKS DIRECTOR.
- 7. 2% MAXIMUM GRADE BREAK BETWEEN DRIVEWAY AND APPROACH.
- 8. INSTALL ONE 2" DIAMETER PVC STREET LIGHT CONDUIT.

