



NOTES:

1. PLACE ONE 3/4 DIA. SUPPORTING BOLT EVERY 6' OF OPENING, SPACED EVENLY OVER THE ENTIRE OPENING WHERE SIDEWALK EXISTS ADJACENT TO CATCH BASIN. TOP SLAB SHALL BE EXTENDED TO JOIN SIDEWALK.
2. SEE STANDARD PLAN 212 FOR WALL AND FLOOR REINFORCEMENT
3. LOCAL DEPRESSION SHALL BE 6" THICK
4. ALL METAL SHALL BE GALVANIZED AFTER FABRICATION
5. WHEN "W" EXCEEDS 15', PROVIDE MANHOLE AT EACH END.
6. SEE STANDARD PLAN 210 AND 211 FOR FACE PLATE AND PROTECTION BARS.
7. LOCAL DEPRESSION MAY BE OMITTED AND STANDARD GUTTER WIDTH USED FOR INLETS WITH A STREET GRADE OF 6% OR MORE.

REVISIONS:		
NO.	DATE	APPRV'D
1	3-16-16	N119

APPROVED BY:

Kip D. Field 11/23/09

CITY ENGINEER DATE

KIP D. FIELD

RCE NO. 45679 EXP. DATE 12-31-16

CITY OF CORONA

**CATCH BASIN
TYPE "B"**

STANDARD PLAN NUMBER: **205** SHT 1 OF 1