


D	L	T
12"	1.0'	4"
18"	1.0'	5"
24"	1.0'	5"
36"	1.5'	8"
48"	1.5'	10"
57"	1.5'	10"
60"	1.75'	11"
66"	1.75'	11"

NOTES:

1. A CONCRETE COLLAR IS REQUIRED WHERE THE CHANGE IN GRADE EXCEEDS 0.10 FOOT, OR AS REQUIRED BY THE INSPECTOR.
2. WHERE PIPES OF DIFFERENT DIAMETERS ARE JOINED WITH CONCRETE COLLAR, L AND T SHALL BE FOR THE LARGER DIAMETER PIPE.
3. FOR PIPE LARGER THAN 66" A SPECIAL COLLAR DETAIL IS REQUIRED.
4. FOR PIPE SIZE NOT LISTED USE NEXT SIZE LARGER.
5. ALL CONCRETE SHALL BE 560-C-3250.
6. PIPE SHALL BE REINFORCED CONCRETE PIPE, UNLESS OTHERWISE NOTED.
7. THE DIAMETER OF THE CIRCULAR TIES SHALL BE $D + (2 \times \text{WALL THICKNESS}) + 8"$.
8. WHEN D1 IS EQUAL TO OR LESS THAN D2, JOIN INVERTS AND WHEN D1 IS GREATER THAN D2, JOIN SOFFITS.



APPROVED BY:

 CITY ENGINEER
 KIP D. FIELD

11/23/09
 DATE

REVISION	DESCRIPTION	BY	DATE

CITY OF CORONA

CONCRETE COLLAR

STANDARD PLAN NUMBER: **216** SHT 1 OF 1