



**NOTES:**

1. 6" WIDE ALUMINUM EXTRUSION, 0.090" THICK WITH A 0.250" SUPPORT CHANNEL ALONG THE TOP & BOTTOM EDGE. (WESTERN HIGHWAY PRODUCTS, TYPE AX06 OR APPROVED EQUAL)  
BLUE BACKGROUND WITH 4" WHITE LETTERS (ALL CAPITALS C-SERIES, FOR STREET NAME  
2" WHITE, C-SERIES, FOR STREET NAME SUFFIX, AND BLOCK NUMBER.

**NOTES:**

- ALL BACKGROUND & LETTERED MATERIAL SHALL BE REFLECTORIZED. BLUE BACKGROUND (#2275 ZUMAR ROLL SHEETING DIAMOND GRADE OR APPROVED EQUAL).
2. DIE CAST ALUMINUM 90° CROSSPIECE (ZUMAR STYLE 859 SHORT OR APPROVED EQUAL). NOTE SIGNS 36" TO 48" USE 850 LONG CROSSPIECE.
  3. 2" SQUARE TUBE DIE CAST ALUMINUM CAP (ZUMAR STYLE 850 SHORT OF APPROVED EQUAL). NOTE: SIGNS 36" TO 48" USE 850 LONG CAP
  4. #457 USED FOR INSTALLATION ON STREET LIGHT POLES NO. 516. ALUMINUM CANTILEVER BRACKET FOR 6" BLADES (ZUMAR STYLE 730 OR APPROVED EQUAL).
  5. 201 STAINLESS STEEL 3/4" BUCKLE (BAND-IT EDP NO. 13256, CAT NO C256 OR APPROVED EQUAL).
  6. 201 STAINLESS STEEL BAND, 3/4" WIDE x 0.030" THICK (BAND-IT, CAT NO. C206 OR APPROVED EQUAL).
  7. STAINLESS STEEL FLARED LEGS BRACKET WITH BOLT AND WASHER 0.075" THICK CAT NO. 0021.
  8. SIGN POST, 2" X 2" X 10', 12 GAGE, STEEL GALVANIZED PERFORATED 4 SIDES.
  9. POST BASE, 2 1/4" X 2 1/4" X 30", 7 GAGE, STEEL GALVANIZED, HEAVY DUTY ANCHOR.
  10. CONCRETE FOOTING, 8" DIA. BY 30" DEEP, 560-C-3250 PCC.
- NOTE: ALL STREET SIGNS TO BE MOUNTED A MINIMUM OF 7' ABOVE FINISHED GRADE.  
NOTE: CONTACT THE CITY OF CORONA, PUBLIC WORKS DEPARTMENT FOR BLOCK NUMBERS.



APPROVED BY:			
		11/23/09	
CITY ENGINEER		DATE	
KIP D. FIELD			
REVISION	DESCRIPTION	BY	DATE

<b>CITY OF CORONA</b>	
<b>STREET NAME SIGNS</b>	
STANDARD PLAN NUMBER: <b>512</b>	SHT 1 OF 1