



SUPPORT SPACING

WHEN PURPLE UVR PVC PIPING SYSTEMS ARE INSTALLED ABOVE GROUND, THEY MUST BE PROPERLY SUPPORTED TO AVOID UNNECESSARY STRESSES AND POSSIBLE SAGGING. ON HORIZONTAL AND VERTICAL RUNS, SUPPORTS SHALL BE INSTALLED A MAXIMUM OF 10 FEET ON CENTERS.

NOTES:

1. ANCHOR SHALL BE PLACED NO GREATER THAN 10 FT APART FOR LATERAL LINE.
2. ANCHOR SHALL BE 1/2" X 18" REBAR.
3. THE 18" LEG OF THE ANCHOR PIN SHALL BE PLACED ON THE DOWN HILL SIDE FOR ALL SLOPE AREAS.
4. NO MAINLINE AND IRRIGATION WIRES WILL BE ALLOWED ON GRADE.



APPROVED BY:
Kip D. Field 11/23/09
 CITY ENGINEER DATE
 KIP D. FIELD

CITY OF CORONA

PIPE ANCHORING DETAIL

REVISION	DESCRIPTION	BY	DATE

STANDARD PLAN NUMBER: **612** SHT 1 OF 1