


**NOTES:**

1. AREA AROUND BOX CAN EITHER BE PLANTED, HARD SURFACED OR A COMBINATION.
2. TOP OF BOX : AT GRADE FOR LAWN.  
1" ABOVE GRADE FOR GROUND COVER.
3. 3/4" CRUSHED ROCK SHALL COVER VALVE BOX PIPE OPENINGS TO PREVENT SOIL ENTRY.
4. USE PLASTIC LOCKING VALVE BOXES EXCEPT IN SIDEWALK OR SLAB AREA.
5. USE OF DUAL UNION BALL VALVES IS PROHIBITED.
6. TEFLON TAPE IS REQUIRED ON ALL THREADED CONNECTIONS.
7. ALL 2 1/2" VALVES OR LARGER SHALL BE PLACED IN A 10" ROUND LOCKING VALVE BOX.



APPROVED BY:  
  
 11/23/09  
 CITY ENGINEER DATE  
 KIP D. FIELD

**CITY OF CORONA**

**GATE VALVE**

REVISION	DESCRIPTION	BY	DATE

STANDARD PLAN NUMBER: **806**

SHT 1 OF 1