


NOTES:

1. ALL NIPPLES SHALL BE SCHEDULE 80 PVC UNLESS OTHERWISE SPECIFIED.
2. TEFLON TAPE REQUIRED ON ALL BUT MARLEX FITTINGS.
3. ALL PIPING AND FITTING SHALL BE THE SAME SIZE AS THE SPRINKLER INLET.



APPROVED BY:
Kip D. Field
 CITY ENGINEER
 KIP D. FIELD

11/23/09
 DATE

CITY OF CORONA

SWING JOINT DETAIL

REVISION	DESCRIPTION	BY	DATE

STANDARD PLAN NUMBER: **814** SHT 1 OF 1