


NOTES:

1. CONCRETE SHALL BE CLASS 560-C-3250 PCC, CURED WITH CURING COMPOUND.
2. ALL EXPOSED CORNERS SHALL BE FINISHED WITH 1/2" RADIUS.
3. FINISH SHALL BE FINE BROOM.
4. EXISTING PCC SHALL BE SAWCUT AT JOINT PRIOR TO REMOVAL.
5. CURBS SHALL HAVE COLD JOINTS AT BCR AND ECR AND AT 10' INTERVALS ONLY.
6. WHEN CURB AND GUTTER IS PLACED BY AN EXTRUSION MACHINE, FINISHING WORK SHALL PROVIDE AN ACCEPTABLE FINISH.



APPROVED BY:
Kip D. Field 11/23/09
 CITY ENGINEER DATE
 KIP D. FIELD

CITY OF CORONA

TYPE 6A CURB

REVISION	DESCRIPTION	BY	DATE

STANDARD PLAN NUMBER: **137** SHT 1 OF 1