



**SIDEWALK SHALL MEANDER AS DETERMINED  
BY THE PUBLIC WORKS DIRECTOR**

**NOTES:**

1. THICKNESS OF SIDEWALK SHALL BE 4" EXCEPT IN DRIVEWAY APRONS WHERE 6" IS REQUIRED FOR RESIDENTIAL DRIVEWAYS AND 8" IS REQUIRED FOR COMMERCIAL AND INDUSTRIAL DRIVEWAYS.
2. SIDEWALK SHALL HAVE 1-1/2" DEEP WEAKENED PLANE JOINTS AT INTERVALS SHOWN HEREON. JOINTS SHALL HAVE EDGES WITH 1/8" RADII.
3. CONCRETE SHALL BE CLASS 560-C-3250, CURED WITH CURING COMPOUND.
4. PARKWAY FROM CURB TO PROPERTY LINE TO BE BROUGHT TO GRADE BY CONTRACTOR BEFORE FINAL APPROVAL AND COMPACTED 90%.
5. SIDEWALKS SHALL BE FORMED IN SUCH A MANNER AS TO MAINTAIN 36" MINIMUM OF UNOBSTRUCTED PEDESTRIAN WAY AT ALL LOCATIONS, INCLUDING BUT NOT LIMITED TO ELECTROLIERS, POWER POLES, AND FIRE HYDRANTS.



APPROVED BY:  
  
 11/23/09  
 CITY ENGINEER DATE  
 KIP D. FIELD

**CITY OF CORONA**

---

**MEANDERING SIDEWALK**

| REVISION | DESCRIPTION | BY | DATE |
|----------|-------------|----|------|
|          |             |    |      |

STANDARD PLAN NUMBER: **143** SHT 1 OF 1