



(4) # 4 REBAR,
ONE @ EA.
CORNER
(SOLID GROUT)

6' MAX

ALL
FOOTINGS
SHALL BE A
MINIMUM 5' TO
DAYLIGHT

NOTE: PILASTERS BUILT IN CONJUNCTION WITH CITY STANDARD RETAINING WALL MUST HAVE CONTINUOUS FOOTING AND BOND BEAM. SEE RETAINING WALL STANDARD FOR FOOTING DIMENSIONS, AND BOND BEAM LOCATION.

INSPECTIONS REQUIRED

1. FOUNDATION: EXCAVATION, TRENCH CLEAN WITH STEEL IN PLACE.
2. STEEL: INSPECT BEFORE GROUTING.
3. FINAL: AFTER GROUT, PRIOR TO CAPPING



BUILDING DEPARTMENT

PILASTER STANDARD DETAIL

(951) 736-2250

400 S. VICENTIA AVE. CORONA, CA. 92882-2187

FAX (951) 739-4893

03/23/2005

\PILASTER.VSD

1 OF 1